



Telephone: +91-40-20203009	Date: 14.11.2023
Website : www.tifrh.res.in	Email: krishnaae@tifrh.res.in

PUBLIC TENDER

(TWO PART TENDER) for the following works:

Supply, Installation, Testing and Commissioning of Air Handling Units for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.	
Tender No.	TIFR/PD/CA23-91/231054
Type of Tender	Two Part Tender (Part-I: Technical Bid and Part- II: Price Bid)
Estimated Cost	Rs.1,54,98,688/-
Cost of EMD`	Rs.3,10,000/- (Demand Draft to be drawn in favor of "TIFR Center for Interdisciplinary Sciences", Payable at Hyderabad (To be enclosed with the Technical Bid Part – I).
Pre bidding meeting & Time	17.11.2023 at 11:00 Hrs
Last Date for Submission of Tender	21.11.2023 by 13:00 Hrs
Date of Opening Bids(Only Part-I: Technical Bid)	21.11.2023 at 16:30 Hrs
Tender Fee	Rs.1000/- (Demand Draft to be drawn in favor of "TIFR Centre for Interdisciplinary Sciences "Payable at Hyderabad (To be enclosed with the Technical Bid Part –I)).

- In case the Part "I" and Part "II" bids are not sealed in separate envelopes the tender will be rejected.
- The technical bid should not contain any indication of the price.
- The Technical Bid received without payment of tender fees and EMD shall be summarily rejected.
- Contacts: Mr. Krishna, Tel: 040- 20203009/3003 for any technical or commercial terms clarifications mentioned in the tender.



TATA INSTITUTE OF FUNDAMENTAL RESEARCH
(Autonomous Institution of the Department of Atomic Energy, Government of India)
Survey No.36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District,
Hyderabad-500046, Telangana

Sealed tenders are invited for the aforesaid works from contractors having similar work experience in reputed Research Institutions, Universities, Central Government/Public Sector Undertaking, Private Laboratories, Multinational Companies, etc. Interested contractors who are satisfying prequalification criteria stipulated by TIFR-Hyderabad shall only submit their bids. For further details and any clarification on the tender you may please contact Head-Technical Services, Survey No.36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad-500046.

Last date for submission of the tender is 21.11.2023 by 13:00 Hrs.

A handwritten signature in black ink, appearing to read 'Rajasekhar. R', is written over a faint circular stamp.

(Rajasekhar. R)

Head-Technical Services



TENDER DOCUMENT

**Supply, Installation, Testing and Commissioning of Air Handling
Units for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally
(Village), Serilingampally (Mandal), Ranga Reddy Dist.,
Hyderabad-500046.**

NAME OF THE TENDERER:.....

Address:

.....

.....

.....

Last date of submission of the tender: On or before 21.11.2023 by 13:00 Hrs



TECHNICAL BID

VOLUME-I

**Supply, Installation, Testing and Commissioning of Air Handling
Units for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally
(Village), Serilingampally (Mandal), Ranga Reddy Dist.,
Hyderabad-500046.**



Tender Notice	:	TIFR/PD/CA23-91/231054
Name of Work	:	Supply, Installation, Testing and Commissioning of Air Handling Units for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.
Location	:	Tata Institute of Fundamental Research Survey No. 36/P, Gopanpally village, Serilingampally Mandal, Ranga Reddy District, Hyderabad – 500046.
Estimated Cost	:	Rs.1,54,98,688/-
EMD	:	Rs.3,10,000/- (Demand Draft to be drawn in favor of “TIFR Center for Interdisciplinary Sciences”, Payable at Hyderabad (To be enclosed with the Technical Bid Part – I).
Delivery Period	:	180 Days (Completion Period)
Validity	:	Seventy Five (75) days after opening of Part-I, Technical Bid

INDEX

SECTION	DESCRIPTION	PAGE NO.
SECTION I	IMPORTANT INFORMATION	7-9
SECTION II	ELIGIBILITY CRITERIA FOR QUALIFICATION OF TENDER	10-17
SECTION III	NOTICE & INSTRUCTIONS	18-22
SECTION IV	GENERAL INFORMATION	23-42
SECTION V	ANNEXURES	43-51
SECTION VI	FINANCIAL BID (PART II)	52-63



SECTION-I

IMPORTANT INFORMATION

INTRODUCTION

The Tata Institute of Fundamental Research is a National Centre of the Government of India, under the umbrella of the Department of Atomic Energy, as well as a deemed University awarding degrees for master's and doctoral programs. Tata Institute of Fundamental Research Centre for Interdisciplinary Sciences, Hyderabad invites bids for the following work:

Supply, Installation, Testing and Commissioning of Air Handling Units for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.

1. PARTICULARS

a)	Location	TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.
b)	Pre-Bid Meeting Date & Time	17.11.2023 at 11:00 Hrs
c)	Closing date & time of receipt of bids	21.11.2023 by 13:00 Hrs
d)	Date & time of opening of Sealed Cover-I containing Technical Bid	21.11.2023 at 16:30 Hrs
e)	Date of opening of Sealed cover-II containing Financial Bid of eligible bidders	To be intimated to eligible bidders subsequently which is likely to be within 7 days after opening Technical Bid

2. GENERAL INSTRUCTIONS

- 2.1. TIFR shall award the contract for the project through the two Bid systems.
- 2.2. The Contractor is advised to visit and examine the site of work and its surroundings and obtain any information that may be necessary, in addition to those provided in this document. The Contractor shall be deemed to have fully acquainted himself about the site condition, whether he inspects it or not.
- 2.3. The Contractor should adhere to the building bye-laws applicable for the area.
- 2.4. All clarifications shall be sought before the date of pre-bid meeting. The bidders may make suggestions which shall be considered during the Pre Bid Meeting. No further clarifications shall be issued after the issue of noteworthy replies to the pre-bid queries.
- 2.5. The submission of the bid by Contractor would imply that they have carefully read and agreed to the terms and conditions contained in this bid document.

- 2.6. The bid for the work shall remain open for acceptance for a period of 75(seventy five) days from the date of submission of the bids, which period may be extended by mutual agreement and the Contractor shall not cancel or withdraw the offer during this period.
- 2.7. This bid document shall form a part of the contract agreement.

3. SUBMISSION OF BIDS

Bids shall be submitted to Head- Technical Services, **TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist, Hyderabad-500046** in a sealed Master envelope super scribed "Bid for **Supply, Installation, Testing and Commissioning of Air Handling Units for Petawatt Laser Facility at TIFR** with our enquiry no. and due date, containing two separate sealed covers clearly super scribed as "**Technical Bid**" and "**Financial Bid**" before the closing date and time of submission in the following manner:

- a) "**Technical Bid**": This will contain Technical part, Eligibility Documents along with testimonials. Earnest Money Deposit (EMD).
- b) "**Financial Bid**": This will contain the complete bidding document with duly filled in Schedule of Financial Quote of Financial Bid & Tender Drawings.

The Bids without signature of the authorized person of bidder and seal, without EMD, with conditions or conditional rebates shall be summarily rejected.

4. EVALUATION OF BID

- 4.1. **EVALUATION OF TECHNICAL BID**: The bids received will first be first opened and will be examined for EMD/ Declaration Letter, Eligibility Criteria, Conditions, etc. Conditional Tenders and Tenders without EMD/Declaration Letter shall be summarily rejected.
- 4.2. **EVALUATION OF FINANCIAL BID**: The Financial Bid should contain the complete bid document with duly filled in Schedule of Financial Quote of Financial Bid and signed Tender drawings. Financial Bids of Technically qualified Bidders will only be opened. Work will be awarded to lowest bidder (L1) based on their quotes after making necessary arithmetical checks.

5. SCOPE & OBJECTIVE

The Objective of the tender is to **Supply, Installation, Testing and Commissioning of Air Handling Units for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046** as per the specifications and Bill of quantities mentioned in the Financial Bid.

Period of Completion of Work: 180 days from the date of issue of work order

Defect Liability Period: 12 months from the date of handing over of completed system as per tender.



6. PAYMENT SCHEDULE:

The contractor shall submit the bills for payments along with a detailed statement showing the actual works carried out under different heads of items in the format specified by the TIFR. Minimum value of the work for interim payment (**two Running Bill**) shall be 35% of the work order value. All interim and final bills will be settled based on the joint measurements of each item of work and certified by TIFR Engineer. The bills for nonperishable materials on site may also be submitted and the payment by TIFR against the same shall be to the maximum extent of 60% of the value of these materials on production of sufficient documentary evidence ie. Original invoice, Inventory, etc. All interim bills will be paid within **15** days from the date of submission and Final Bill along with all relevant documents will be settled within **30** days from the date of submission with certification of TIFR Engineer.

SECTION-II

ELIGIBILITY CRITERIA FOR TENDER QUALIFICATION

Supply, Installation, Testing and Commissioning of Air Handling Units for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.

• **Eligibility criteria:**

1. The Agencies/Contractors shall hold a valid labor license issued by appropriate authority and must be valid throughout the contractual period
2. IT Returns for the last three consecutive financial years ended on March 31, 2023 audited by CA.
3. The Agencies/Contractors should have an average annual turnover of **Rs.61.99** lakhs during three previous financial years ending March 31, 2023.
4. The Agencies/Contractors should have a latest solvency certificate issued by any nationalized bank of value not less than **Rs.61.99** Lakhs.
5. The Agencies/Contractors should not have incurred any loss in more than two years during the immediate last five consecutive financial years, duly certified by the Chartered Accountant.
6. The Agencies/Contractors should have valid PAN from Income Tax Authority, GST registration No. etc. and any other registration applicable/mandatory for contract.
7. Submission of technical data sheets of AHU'S (Annexure-V)
8. The Agencies/Contractors should have executed similar installations of Air conditioning systems for Clean rooms or similar works successfully at least
 - 8.1. One similar work costing **Rs.1.24 Crores** or
 - 8.2. Two similar works costing **Rs.92.99** Lakhs or
 - 8.3. Three similar works costing **Rs.61.99** Lakhs during the last 7 financial years ended on the end date of receiving tender for Research Institutes, Universities, Private Laboratories, R & D institutes, etc. in any Government /PSU/Private organizations of repute.

The Agencies/Contractors should furnish copies of work orders along with BOQ and completion certificates are mandated from the clients in support of the above.

Note:

- ❖ Agencies/Contractors are advised to inspect the site to understand the scope of work comprehensively before submission of tender.
- ❖ Agencies/Contractors should arrange the site inspection to TIFR officials for the qualifying works at their own cost if required.
- ❖ Agencies/Contractors should have a full-fledged in-house project management team to undertake the jobs.



TATA INSTITUTE OF FUNDAMENTAL RESEARCH

(Autonomous Institution of the Department of Atomic Energy, Government of India)
Survey No.36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District,
Hyderabad-500046, Telangana

- ❖ The Agencies/Contractors shall **strictly furnish** aforesaid information in the formats/schedules given. **Non adherence to furnishing of information in the given format/schedules given will lead to disqualification of tender.**
- ❖ Instructions to Agencies/Contractors for furnishing the information is given as under:
 - Each page of the application shall be signed by a person having necessary authority to do so.
 - If the space in the proforma is insufficient for furnishing full details, such information may be given in separate sheets.
 - Applicants are required to furnish information against each item of the application. In case a certain item is not applicable, please write NA. Application containing incorrect and or inadequate information is liable to be rejected.



SCHEDULE – A
BASIC INFORMATION

1. Name of the firm :
2. a) Address :
- b) Telephone / Fax No. :
- c) Mobile No. Contact Person :
- d) PAN No. :
- e) GST Registration No. :
- f) Labour License Details :
- Branch Office if any in Hyderabad :
3. Type of Organization :
(Proprietorships / Partnership) Ltd. Co. /
Co-Operative) (Copy of relevant document
to be enclosed)
4. Date of Incorporation :
5. Nature of Business :
6. Experience as prime Agencies/
Contractors (in Yrs.) :
7. Name and address of Bankers :
8. Organization chart of the Company :
including names and positions of directors
/ key personnel

Signature of the Applicant (s)



SCHEDULE – B

Major AC works (Copies of the completion certificate to be enclosed)

A. Similar work of costing Rs.1.24 Crores or two similar works of costing Rs.92.99 lakhs or 3 similar works of costing Rs.61.99 Lakhs during last 7 financial years ended on end date of receiving tender for Research Institutes, Universities, Private Laboratories, R & D institutes, etc

Sr. No	Name of the project & Address	Description of work in brief	Name of the Engineer	Name of the client also indicate whether Govt or semi Govt or Pvt body with full postal address	Contract Amount in Rs.	Year of commencement	Date of Completion		Whether work was left /uncompleted or the contract was terminated from either side? Give Details.	Any other relevant information relevant information
							Stipulated	Actual		
1.										
2.										



TATA INSTITUTE OF FUNDAMENTAL RESEARCH
(Autonomous Institution of the Department of Atomic Energy, Government of India)
Survey No.36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District,
Hyderabad-500046, Telangana

B. List of works in progress above Rs.61.99 lakhs.

S No.	Name of the project & Address	Description of work in brief	Name of the Engineer with full postal address	Name of the Client. Also indicate whether Govt. or semi Govt. or Pvt. Body with full postal address	Contract Amount in (Rs.)	Date of Completion	Present stage of work with reasons if the work is getting delayed	Any other relevant information
1.								
2.								

Signature of the Applicant (s)



SCHEDULE – C

TECHNICAL PERSONNEL & SPECIAL EXPERIENCE

List of technical personnel in your establishment giving details about their technical qualification and experience

Sr No	Name	Age	Qualifications	Project Experience	Nature of works handled	Name of the project Handled	Date from which employed in your organization	Indicate special experience in Air Conditioners installation & Testing projects in which were employed
1								
2								

2. Indicate other points if any to show your technical and managerial competency to indicate any important point in your favour.

Signature of the Applicant (s)



SCHEDULE – D

FINANCIAL POSITION AND WORKING RESULTS

		2020-21	2021-22	2022-23
1	Annual turnover	:	Rs.	
2.	Net Profit	:	Rs.	
3.	Credit Facilities from the Bank	:	Rs.	
	a) Cash Credit	:	Rs.	
	b) Overdraft Limit	:	Rs.	
	c) Guarantee	:	Rs.	
	d) Others	:	Rs.	
4.	Certificate from the Bankers regarding financial soundness of the applicant	:	Enclosed (Yes / No)	
5.	Solvency Certificate from the Bankers	:	Enclosed (Yes / No)	

Signature of the Application (s)



SCHEDULE – E

MISCELLANEOUS INFORMATION

- 1 Whether it would be possible to process Bank :

 Guarantee for various advances
 during execution of the work.

- 2 Details of Civil Suits / Litigations arose during :
 execution of the contracts in the last 5 years.

- 3 Latest Income Tax Clearance Certificate :

- 4 Name of the two senior official of :
 Organizations preferably Govt./Semi Govt/
 Autonomous/ Public Sector Organization for
 whom you have executed important and
 major AHU works, who may be directly
 contracted by TIFR to gather information
 about your ability, competence and capacity
 of your work/organization/etc.

- 5 Number of Supplementary sheets attached. :

Signature of the Applicant (s)

SECTION-III	NOTICE & INSTRUCTIONS
--------------------	----------------------------------

1. **Sealed item rate tenders** in the prescribed form are invited from Head-Technical Services, Tata Institute of Fundamental Research, Centre for Interdisciplinary Services, Hyderabad, for the following:

Tender Notice No.	
Name of Work	Supply, Installation, Testing and Commissioning of Air Handling Units for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.
Estimated Cost	Rs.1,54,98,688/-
Time Limit	180 days (Completion Period)
Earnest Money Deposit	Rs.3,10,000/- (Demand Draft to be drawn in favor of "TIFR Centre for Interdisciplinary Sciences "Payable at Hyderabad (To be enclosed with the Technical Bid Part -I)).
Tender Fee	Rs.1000/- (Rupees Five Hundred only) (Demand Draft to be drawn in favor of "TIFR Centre for Interdisciplinary Sciences "Payable at Hyderabad (To be enclosed with the Technical Bid Part -I)).
Last Date & Time of Submission of Tender	21.11.2023 by 13:00 Hrs
Date & Time of Opening of Technical Bid	21.11.2023 at 16:30 Hrs

2. **Submission of Tender & Opening:**

Tenders shall be submitted in a sealed envelope super scribed with Tender enquiry No., Due Date and with heading as **"Supply, Installation, Testing and Commissioning of Air Handling Units for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046."** containing two separate sealed covers clearly super scribed as **"TECHNICAL BID"** and **"FINANCIAL BID"** on or before the closing date and time of submission in the following manner:

"TECHNICAL BID": This will contain the following:

- a) Proof of Tender Cost paid already
- b) Earnest Money Deposit as stipulated
- c) Schedules giving information on Eligibility Criteria with supporting documents specified for tender qualification.

“FINANCIAL BID”: Signed copy of the Financial Bid quoting amount in the stipulated format and signed copies of the tender drawings.

3. Earnest Money Deposit (EMD): EMD shall be submitted in the form of Demand Draft / Pay Order / Banker’s cheque issued by a Scheduled Bank, drawn in favor of **“TIFR Center for Interdisciplinary Sciences”**, (To be enclosed with the Technical Bid (Part-I))

Earnest Money Deposit (EMD): Every Bidder has to pay EMD of amount as specified elsewhere in this tender by Demand Draft in favor of **“TIFR Center for Interdisciplinary Sciences”** along with the offer. Quotations received without EMD shall be rejected and no correspondence whatsoever will be entertained. For successful bidders the EMD will be adjusted against Performance Guarantee and will be refunded after completion of work /supply of material at site and for unsuccessful bidders EMD will be refunded after placing the order to successful bidder.

4. Performance guarantee/Security Deposit:

The tenderer, whose tender is accepted, will be required to furnish a performance guarantee/security deposit of 2.5% of the tendered amount within 7 (seven) working days from the date of intimation. This guarantee shall be in the form Demand Draft / Pay Order / Banker’s cheque / Deposit or Government Securities / Fixed Deposit Receipt (FDR) or Guarantee Bonds (BG) of any Scheduled Bank in accordance with the form as Annexure – I hereto. In case a fixed deposit receipt of any Bank is furnished by the contractor to TIFR as part of the performance guarantee and the Bank is unable to make payment against the said fixed deposit receipt, the loss caused thereby shall fall on the contractor and the contractor shall forthwith on demand furnish additional security to TIFR to make good the deficit.

The Performance Guarantee shall be initially valid up to the stipulated date of completion **plus 60 days** beyond that. In case the time for completion of work gets enlarged, the contractor shall get the validity of performance Guarantee extended to cover such enlarged time for completion of work. The performance guarantee shall be returned to the contractor, without any interest, after recording of the completion certificate for the work by the competent authority.

The Engineer-in-charge shall make a claim under the Performance guarantee for amounts to which TIFR entitled under the contract (notwithstanding and / or without prejudice to any other provisions in the contract agreement) in the event of:

- a) Failure to attend and rectify the problems in the guarantee period, in which event the Engineer- in-charge may claim the full amount of the Performance guarantee.

- b) Failure by the contractor to pay TIFR, Hyderabad any amount due, either as agreed by the contractor or determined under any of the Clauses / Conditions of the agreement, within 30 days of the service of notice to this effect by Engineer-in-charge.

In the event of the contract being determined under provisions of any of the relevant clauses of the agreement, the performance guarantee shall stand forfeited in full and shall be absolutely at the disposal of TIFR, Hyderabad.

5. Security Deposit: The tenderer, whose tender is accepted, will also be required to furnish by way of Security Deposit for fulfillment of his contract, an amount equal to 5% of the tendered value of the work. Earnest Money deposited at the time of tenders will be treated as part of the Security Deposit.

or

The successful tenderer shall permit TIFR, Hyderabad at the time of making any payment to him for work done under the contract to deduct a sum at the rate of 5% of the gross amount of each running bill till the sum along with the sum already deposited as earnest money, will amount to security deposit of 5% of the tendered value of the work. Such deductions will be made and held by TIFR by way of Security Deposit unless he has / they have deposited the amount of Security at the rate mentioned above in cash or in the form of Fixed Deposit Receipts.

In case a fixed deposit receipt of any bank is furnished by the contractor to TIFR, Hyderabad as part of the security deposit and the bank is unable to make payment against the said fixed deposit receipt, the loss caused thereby shall fall on the contractor and the contractor shall forthwith on demand furnish additional security to TIFR, Hyderabad to make good the deficit.

All compensation or the other sums of money payable by the contractor under the terms of this contract may be deducted from, or paid by the sale of a sufficient part of his security deposit or from the interest arising there from, or from any sums which may be due to or may become due to the contractor by TIFR or any account whatsoever and in the event of his Security Deposit being reduced by reason of any such deductions or sale as aforesaid, the contractor shall within 10 days make good in cash or fixed deposit receipt tendered by the State Bank of India or by scheduled banks (if deposited for more than 12 months) endorsed in favor of the TIFR, HYDERABAD, any sum or sums which may have been deducted from, or raised by sale of his security deposit or any part thereof.

Security Deposit shall be initially valid up to one year from the date of completion of work. In case the time for completion of work gets enlarged, the contractor shall get the validity of Security Deposit extended to cover such enlarged time for completion of work. The Security Deposit shall be returned to the contractor, without any interest, after completion of defect liability period.

Security Deposit as deducted above can be released against Bank Guarantee issued by a Scheduled Bank on its accumulation to a minimum of Rs.5 Lakhs subject to the condition that amount of such Bank Guarantee, except last one, shall not be less than Rs.5 Lakhs. Bank Guarantee should be submitted which will be valid upto the expiry of defect liability period.

6. Acceptance of Tender: The competent authority, on behalf of TIFR, Hyderabad does not bind itself to accept the lowest or any other tender, and reserves to himself the authority to reject any or all the tenders received, without assignment of any reason. All tenders, in which any of the prescribed conditions is not fulfilled or any condition, including that of conditional rebates, is put forth by the tenderer, shall be summarily rejected.

The Competent Authority, on behalf of TIFR, Hyderabad reserves to itself the right of accepting the whole or any part of the tender and the tenderer shall be bound to perform the same at the rates quoted. The officer inviting tenders shall have the right of rejecting all or any of the tenders and will not be bound to accept the lowest tender or any other tender.

7. Validity of Tender: The tender for the work shall remain open for acceptance for a period of 75 days from the last date of submission of tenders. If any tenderer withdraws his tender before the said period, or before issue of Letter of Intent, whichever is earlier, or makes any modifications in the terms and conditions of the tender which are not acceptable to the Department, then TIFR, Hyderabad shall, without prejudice to any other right or remedy, be at liberty to forfeit 50% of the said earnest money absolutely. Further the tenderer shall not be allowed to participate in the retendering process of the work.

8. Levy / Taxes payable by contractor:

i. GST or any other tax on materials and services in respect of this contract shall be payable by the contractor and TIFR shall not entertain any claim whatsoever in this respect.

ii. The contractor shall deposit royalty and obtain necessary permits as required for supply of the sand, aggregate, stone etc. from local authorities.

9. Deduction of Income Tax : As per Section 194-C of Income tax Act 1961, as amended by letter No. 275/9/72/9-TJ (Circular No. 86) dated 19.5.72 and No. 275/14/91-IT (B) (Circular No. 593) dated 5.2.91, received from Ministry of Finance, Department of Revenue, Central Board of Direct Taxes, New Delhi, the Income tax @ 2% and Surcharge thereon @12% (or any other amended rate by Ministry of Finance from time to time), of the gross value of the work done will be recovered from the bills. A certificate for the amount recovered will be issued by the Department.

10. Site visit by the tenderer before tendering: Tenderers are advised to inspect and examine the site and its surroundings during working hours and satisfy themselves before submitting their tenders as to the nature of the ground and subsoil (so far as is practicable), the

form and nature of the site, the means of access to the site, the accommodation they may require and in general shall themselves obtain all necessary information as to risks, contingencies and other circumstances which may influence or affect their tender. A tenderer shall be deemed to have full knowledge of the site whether he inspects it or not and no extra charges consequent on any misunderstanding or otherwise shall be allowed.

11. Signing of Tender and receipts for payments: In the event of the tender being submitted by a firm, it must be signed separately by each partner thereof or in the event of the absence of any partner, it must be signed on his behalf by a person holding a power-of-attorney authorizing him to do so, such power of attorney to be produced with the tender, and it must disclose that the firm is duly registered under the Indian Partnership Act-1952. Receipts for payments made on account of work, when executed by a firm, must also be signed by all the partners, except where contractors are described in their tender as a firm, in which case the receipts must be signed in the name of the firm by one of the partners, or by some other person having due authority to give effectual receipts for the firm.

12. Tenderer's responsibilities: The tenderer shall be responsible for arranging and maintaining at his own cost all materials, tools & plants, facilities for workers and all other services required for executing the work unless otherwise specifically provided for in the contract documents. Submission of a tender by a tenderer implies that they have read this notice & all other contract documents, and has made himself aware of the scope & specifications of the work to be done and local conditions and factors having a bearing on the execution of the work.

13. Signing of contract: The Notice Inviting Tender shall form a part of the contract document. The successful tenderer / contractor, on acceptance of his tender by the Accepting Authority, shall, within 15 days from the stipulated date of start of the work, sign the contract consisting of: the Notice Inviting Tender, all the documents including all conditions, specifications and drawings, if any, forms the tender as issued at the time of invitation of tender and acceptance thereof together with any correspondence leading thereto.

14. Canvassing, either directly or indirectly, in connection with the tenders is strictly prohibited and the tenders submitted by the contractors who resort to canvassing will be liable to rejection and may be barred from future participation in TIFR works.

Head-Technical Services
For and on behalf of TIFR, Hyderabad

SECTION-IV

GENERAL CONDITIONS OF CONTRACT

1. Definition of Terms:

1.1. In constructing these general conditions and the specifications the following works shall have the meanings herein assigned to them unless there is something in the subject or context inconsistent with such construction.

1.2. The 'Purchaser' shall mean Tata Institute of Fundamental Research- -Hyderabad, Tata Institute of Fundamental Research, 36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad 500046 and shall include the Purchaser's heirs, successors and assigns.

1.3. The term 'Engineer In-Charge' and 'Engineer' shall mean Engineer In-Charge, TIFR-Hyderabad or some other person for the time being or from time to time duly appointed in writing by the Purchaser to act as Engineer In-Charge for the purpose of the Contract or in default of such appointment the Purchaser.

1.4. The term 'Contractor'/'Supplier'/'Bidder'/'Vender' shall mean the Bidder whose tender has been accepted by the Owner and shall include the Bidder's heirs, successors and assigns approved by the Purchaser:

1.5. The term 'Sub-Contractor' shall mean the firm or persons named in the contract for any art of the work or any person to whom any part of the work has been sublet with the consent in writing of the Engineer In-Charge and shall include his heirs, successors and assigns approved by the Purchaser.

1.6. The Term 'Inspector' shall mean any person appointed by or on behalf of the Purchaser to inspect supplies, stores or work under the contract or any person deputed by the Inspector for the purpose.

1.7. The term 'Particulars' shall mean, the following :

1.7.1. Specifications

1.7.2. Drawing (ANNEXURE-IV)

1.7.3. Sealed Pattern denoting a pattern sealed and signed by the Inspector.

1.7.4. Proprietary make denoting the product of an individual firm.

1.7.5. Any other details governing the construction, manufacture and/or supply as existing for the contract.

1.8. The term 'Specification' shall mean the specifications annexed to or issued with these Conditions of Contract.

1.9. The term 'Site' shall mean the place or places at which the Equipment is to be delivered or work done by the Contractor; and shall include, where applicable, the lands and buildings upon or in which the works are to be executed and shall also include the place or places at which fabrication and other work is being carried out by the Contractor.

1.10. 'Electrical Equipment', 'Stores', 'Work' or 'Works' shall mean and include equipment and materials to be provided and work to be done by the Contractor under the Contract.

1.11. The 'Contract' shall mean acceptance of the work order placed on contractor/supplier under section (2) of these conditions and shall include these conditions of Contract, Specifications, Schedule, Drawing, Letter of Intent of the Purchaser and any subsequent amendments mutually agreed upon.

1.12. 'Tests on Completion' shall mean such tests which are prescribed by the specifications or have been mutually agreed to between the Contractor/Supplier and the Purchaser to be made before the equipment is taken over by the Purchaser.

1.13. 'Writing' shall include any manuscript, typewritten or printed statement under or over signature or seal as the case may be. Words importing 'person' shall include firms, companies, corporations and association of individuals whether incorporated or not.

1.14. Words importing singular shall also include plural and vice versa where context requires.

1.15. Bidders are advised to visit and inspect the work-site to make themselves fully conversant with the site conditions and nature of work. Any claim by them after the opening of bids on account of themselves being unaware of any site condition shall not be entertained.

2. Contract

Contractor/Supplier/Manufacturer should send their acceptance letter on receipt of 'Letter of Intent' or 'Work Order' or 'Purchase Order' within the stipulated period. On expiry of said period or exorbitant delay in commencing or executing the work, the Purchaser shall not be liable to any claim from the Contractor/ Supplier for work entrusted to and may revoke the contract.

3. Work at Site

3.1. Access to the works shall be allowed only to the Contractor/Supplier, Sub-Contractors or his duly appointed representatives. The Contractor/ Supplier shall not object to the execution of other works by other contractors or tradesmen and shall afford them every facility for execution of their several works simultaneously with his own.

3.2. Work at the Purchaser's premises shall be carried out at such time as the Purchaser may approve but the Purchaser shall give the Contractor/ Supplier all reasonable facilities for the same. The Contractor/Supplier shall provide sufficient fencing, notice boards etc. to guard the works and warn the public.

3.3. The Contractor shall obey Central, Local and State regulations and enactments pertaining to workmen and labour and the Engineer In-Charge shall have the right to enquire into and decide all complaints on such matters. The Contractor should comply with the Minimum Wages Act and should also ensure that safe practices are followed by his people at site.

4. Delays

The Contractor/Supplier shall not be entitled to any compensation for any loss suffered by him on account of delays in commencing or executing the work, whatever the cause for such delays may be, including delays in procuring Government controlled or other materials and delay in obtaining instructions and decisions from the Engineer In-Charge.

5. Taking Over

The equipment when erected at site shall be deemed to have been taken over by the Purchaser when the Engineer In-Charge will have certified in writing that the equipment has fulfilled the contract conditions.

6. Extension of Time

If the Contractor/Supplier is delayed in the progress of work by changes ordered in the work, or by any cause, which the Engineer In-Charge shall decide to justify the delay, then the time of completion shall be extended by a reasonable time. In this regard, Contractor shall maintain proper hindrance register and record all such events with due signature of E-I-C on occurrence of such instants for seeking extension of time. However, no such extension shall be allowed unless requested for extension is made in writing by the Contractor/Supplier to the Engineer In-Charge within 15 days from the date of occurrence of the delay.

7. Liquidated Damages

7.1. For all delays, which do not merit any extension of time, the Contractor/ Supplier shall attract 1% penalty per week for the first 4 weeks of delay and 2% penalty per week for the next 4 weeks of the total contract value. The amount of liquidated damages shall be recoverable from the payment due to the Contractor/Supplier up to maximum of 10% of value of contract.

7.2. The deduction of liquidated damages shall not, however, absolve the Contractor/Supplier of his responsibility and obligations under the contract to complete the work in its entirety and shall also be without prejudice to action by the Purchaser under clause:

‘Termination of Contract by the Purchaser’. After that the same shall be completed by the Purchaser at the Contractor’s/Supplier’s risk and cost.

8. Other Damages:

8.1. The Contractor/Supplier/Manufacturer shall be responsible for all injury to persons, animals or things and for all damage to the works, structure of, and decorative work in the property which may arise from operation or neglect of himself or any of his Subcontractor or of his or Sub-Contractor’s employees, whether such injury or damage may arise from carelessness, accident or any other cause whatever in any way connected with the carrying out of this contract. This clause shall be held to include any damage to buildings, whether immediately adjacent or otherwise, any damage to roads, streets, foot paths, as well as all damage caused to the works forming the subject of this contract by frost or other inclemency of weather. The Contractor/Supplier shall indemnify the Purchaser and hold him harmless in respect of all and any expenses on property as aforesaid and also in respect of any claim made in respect of injury or damage under any acts of Government or otherwise and also in respect of any award of compensation or damages consequent upon such claim. Contractor shall furnish necessary insurance documents (Contractor All Risk Policy) taken for the site before commencement of work.

8.2. The Contractor/Supplier/Manufacturer shall reinstate all damage of every sort mentioned in this clause, so as to deliver up the whole of the contract works complete and perfect in every respect and so as to make good or otherwise satisfy all claims for damage to the property of the Owner/third parties.

8.3. The Contractor/Supplier/Manufacturer shall indemnify the Purchaser against all claims which may be made against the Purchaser, by any member of the public or other party, in respect of anything which may arise in respect of the works or in consequence thereof and shall, at his own expense, effect and maintain, until the work has been ‘Taken Over’ under clause 5.

8.4. The Contractor/Supplier/Manufacturer shall also indemnify the Purchaser against all claims which may be made upon the Purchaser whether under the Workmen’s Compensation Act or any other statute in force during the currency of this contract or at common law in respect of any employee of the Contractor/Supplier or of any of his sub-contractor and shall at his own expense effect and maintain until

the work has been `Taken Over`, with an approved office. Contractor shall furnish a copy of the labour license before commencement of work. If the aforesaid are not applicable contractor should furnish declaration to this effect and shall indemnify TIFR-Hyderabad, Hyderabad for violation of any such compliances.

8.5. The Purchaser, with the concurrence of the Engineer In-Charge, shall be at liberty and is hereby empowered to deduct the amount of any damages compensation costs, charges and expenses arising or accruing from or in respect of any such claims or damages from any sums due to or become due to the Contractor/Supplier.

9. Guarantee and Defects Liability Period:

9.1. The Contractor/Supplier/Manufacturer shall guarantee that all equipment shall be free from any defect due to the defective materials and bad workmanship and that the equipment shall operate satisfactorily and that the performance and efficiencies of the equipment shall be not less than the guaranteed values. The guarantee shall be valid for a period of 12 months after the date of commissioning as certified by the Engineer In-Charge. Any parts found defective shall be replaced free of all costs by the Contractor/Supplier. The services of the Contractor's/Supplier's personnel if requisitioned during this period for such work shall be made available free of any cost to the Purchaser.

9.2. If the defects are not remedied within a reasonable time, the Purchaser may proceed to do so at the Contractor's/Supplier's risk and expense without prejudice to any other rights.

9.3.

10. Terms of Payment

The contractor will be paid only Two Running Account (RA) Bill and Final Bill considering the progress of works based on measurement of works completed. The contractor shall submit the bills for payments along with a detailed statement showing the actual works carried out under different heads of items in the format specified by TIFR-, Hyderabad. Minimum value of the work for interim payment shall be 35% of the work order value.

BILL FORMAT

Tender Item No.	Description of Items (At least 2 lines)	Unit	Tender Quantity	Executed Quantity	Rate	% work done	Amount

NOTE: All quantities in the bill should be cumulative.

All measurements should be in the order of tender sequence and should be recorded in the measurement book. The Measurement should be strictly in the below mentioned format only.

MEASUREMENT FORMAT

Tender Item No.	Description of Item & Location against each Measurement taken	Nos.	Length	Breadth /width	Height	Qty.	Remarks

The works which have been certified for running bills will also be verified along with the final bill and any defects found need to be replaced / rectified by the contractor at his cost. Till the time, the site is handed over in full, it is the contractor's liability to safeguard the works done and completed at site. The Progress of work should not be affected in any way quoting the reason of non-availability of funds / materials / releasing of Running bill. The liability of the contractor is to complete all works in his scope in the scheduled time as per the terms of contract and will not relieve the contractors from his obligations once the Running bill is paid / kept pending.

Final Payment

Payments of Final bill shall be made after deduction of security deposit /Performance guarantee as specified. The Security Deposit / Performance guarantee, shall be refunded on expiry of the Defects Liability Period after rectifying all defects to the satisfaction of the TIFR-Hyderabad/E.I.C. The acceptance of payment of the final bill by the Contractor would indicate that he would have no further claim in respect of the work executed.

11. Special conditions of Contract governing supplies of the Equipment of this Tender:

11.1. Scope:

- 11.1.1. This specification covers the supply of material as per the enclosed details and quantities and supervision of erection/installation, testing and commissioning of the material.
- 11.1.2. The Contractor/Manufacturer/Supplier shall quote for all the materials along with accessories as mentioned in the enquiry.
- 11.1.3. All the supply shall be in accordance with relevant I.S. Specifications and recognized standards.

11.2. Inspection & Testing of Material:

-
- 11.2.1. Contractor/Manufacturer/Supplier shall submit the lists of Type Tests and Routine Tests to be conducted on the material in the Technical Data Sheet.
- 11.2.2. All the materials shall be tested at factory as per IS Specifications of material by Purchaser's Engineer In-Charge/Engineers before dispatch at the cost of Contractor/Manufacturer/Supplier.
- 11.2.3. Contractor/Manufacturer/Supplier shall inform the concerned Engineer In-Charge for inspection and testing in accordance and fix up a suitable date for the same.
- 11.3. **Test Certificates:**
Contractor/Manufacturer/Supplier shall submit the Test Certificates of all materials.
- 11.4. **Taxes & Duty:**
- 11.4.1. Contractor/Manufacturer/Supplier shall quote the basic price of material. Excise Duty, Custom Duty, Sales Tax, GST, Octroi, Delivery Charges, Transit Insurance and/or any other charges, if any, must be indicated separately.
- 11.4.2. TIFR being a research institute of Govt. of India, is eligible for Excise Duty Exemption on equipment supplies. Necessary exemption certificate will be provided by TIFR.
- 11.4.3. Transit Insurance: The Transit Insurance from the point of dispatch to the site of erection shall be in the scope of Supplier and the cost shall be indicated separately.
- 11.5. **Delivery of Material:**
- 11.5.1. The Contractor/Manufacturer/Supplier shall be held responsible for loading of all equipment and for the stores being sufficiently and properly packed for transport by rail, road, sea or air so as to ensure their being free from any loss or damage on arrival at destination. The packing and marking of packages shall be done by and at the expenses of Manufacturer/Supplier. Each package shall contain a packing note quoting purchase order number and detail of the contents.
- 11.5.2. All the materials must be delivered at site i.e. Hyderabad - TIFR at 36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad-500046. The unloading and positioning of all equipment at the designated locations specified by the Engineer In-Charge shall be in the scope of the Supplier. The Supplier shall arrange for handling equipment, labour for rigging, etc. as required.
- 11.5.3. Material must be delivered at site in all respects as mentioned in the Purchase Order.
- 11.6. **Guarantee:**
If during the period of guarantee any fault or defect arises, the material shall be replaced/repared immediately free of cost, as well as any replacement of accessories required shall be done free of cost.

- 11.7. **Mistake in Drawing:**
The Contractor/Supplier shall be responsible for and shall pay for any alterations in works due to any discrepancies, errors or omissions the drawings or other particulars supplied by him whether such drawings or particulars have been approved by the Purchaser or not.
- 11.8. **Responsibility for Completeness:**
Any fittings or accessories which may not be specifically mentioned in the specifications but which are usual or necessary are to be provided by the Contractor/Supplier without extra charge and the equipment must be complete in all details.
- 11.9. **Extra/Deviation items & Variations in quantity**
TIFR-Hyderabad has the right to omit/delete any of the items and also increase/decrease the quantities mentioned in the tender. No claim or any compensation in this regard will be accepted or paid to the contractor. However, if any new /additional items/deviated items are to be executed, the contractor is bound to execute such items with prior approval from TIFR-Hyderabad after furnishing the proper rate analysis for such extra/deviated items
- 11.10. **Rejection of Defective Equipment:**
- 11.10.1. If the equipment after the acceptance thereof is discovered to be defective, notwithstanding that such defects could have been discovered at the time of inspection or found to have failed to fulfill the requirements of the contract or developed defects after the erection within a period of 12 months from the date of erection, even if such erection is done by the Purchaser, he shall be entitled to give a notice on the Contractor/Supplier setting forth details of such defects or failure and the Contractor/Supplier shall, provided such notice is given within a period of 14 months from the date of such erection or acceptance, forthwith make the defective equipment good or alter the same to make it comply with the requirements of the contract at his own cost and further if in the opinion of the Purchaser, the defects are of such a nature that the defects cannot be made good or required without impairing the efficiency or workability of the equipment or if in the opinion of the Purchaser the Equipment cannot be repaired or altered to make it comply with the requirements of the Contract, the Contractor/Supplier shall, provided a notice given by the Purchaser in this behalf within a period of 14 months from the date of erection or acceptance thereof, remove and replace the same with the equipment conforming to the stipulated particulars, in all respects at the Contractor's/Supplier's own cost. Should he fail to do so within a

reasonable time, the Purchaser may reject and replace, at the cost of the Contractor/Supplier, with equipment of the same particulars or if equipment conforming to the stipulated particulars are not in the opinion of the Purchaser readily procurable, such opinion being final, then with the nearest substitutes.

11.10.2. In the event of such rejection the Purchaser shall be entitled to use the Equipment in a reasonable and proper manner for a time reasonably sufficient to enable him to obtain replacement equipment as herein before provided.

11.11. **Inspection and Final Tests:**

All tests necessary to ensure that the Equipment complies with the particulars and guarantee shall be carried out at such place or places as may be determined by the Inspector. Should, however, it be necessary for the final test as to performance or guarantee to be held over until the Equipment is erected at site they shall be carried out within one month of completion of erection.

11.12. **Intimation about Delivery:**

If the Purchaser shall have notified the Contractor/Supplier in writing that the former is not ready to take delivery, no equipment or materials shall be forwarded until an intimation in writing shall have been given to the Contractor/Supplier by the Purchaser that he is ready to take delivery.

11.13. **Delay in erection:**

Wherever erection of an equipment or machinery is the responsibility of the Contractor/Supplier as a term of the contract and in case the Contractor fails to carry out the erection as and when called upon as to do within the period specified by the Purchaser, the Purchaser shall have right to get the erection done through any source of his choice. In such an event, the Contractor/Supplier shall be liable to bear any additional expenditure that the Purchaser may incur towards erection. The Contractor/Supplier shall, however not be entitled to any gain due to such an action by the Purchaser.

11.14. **Definition of Equipment:**

The work 'Equipment' wherever, it appears in these 'Special Conditions of Contract' governing supplier of Equipment in this Tender shall mean all switchgears, panels, etc. or parts thereof or what the Contractor/Supplier agrees to supply under Contract as specified in the work order.

11.15. **Force Majeure:**

Normally Force Majeure shall cover only acts of God, fire, wars, strike, riots and civil commotion, floods, epidemic, quarantine related strikes, freight embargoes, etc. The contractor shall not be liable for any liquidated damages for delay or any failure to perform the contract arising out of Force Majeure conditions, provided that the contractor shall

within ten days from the beginning of such delay notify the department in writing the cause of delay along with convincing supporting evidence. The department once convinced and accepted the reason may extend the supply completion period by a suitable / reasonable margin.

11.16. Termination of Contract by the Purchaser:

- 11.16.1. If the Contractor/Supplier commits any 'Act of Insolvency' or shall be adjudged an Insolvent or shall have an order for compulsory winding up made against him or pass effective resolution for winding up voluntarily, or if the Contractor/Supplier shall suffer any payment under this contract to be attached by or on behalf of any of the creditors of the Contractor/ Supplier, or shall assign the Contract without the prior consent in writing of the Engineer In-Charge, or shall charge or encumber this Contract or any payments due or which may become due to the Contractor/Supplier there under, or if the Engineer In-Charge shall certify in writing to the Purchaser that the Contractor/Supplier –
- 11.16.1.1. has abandoned the Contract, or
 - 11.16.1.2. has failed to commence the works, or has without any lawful excuse these conditions suspended the progress of the works for seven days after receiving from the Engineer In-Charge written notice to proceed, or
 - 11.16.1.3. has failed to proceed with the work with such due diligence and failed to make such due progress as would enable the works to be completed in accordance with the approved programme of work,, or
 - 11.16.1.4. has failed to remove materials from the site or to pull down and replace work for seven days after receiving from the Engineer In-Charge written notice that the said materials or work were condemned and rejected by the Engineer In-Charge under these conditions, or
 - 11.16.1.5. has neglected or failed persistently to observe and perform all or any of the acts matters or things by this contract to be observed and performed by the Contractor for seven days after written notice shall have been given to the Contractor/ Supplier requiring the Contractor/Supplier to observe or perform the same, or
 - 11.16.1.6. has to the detriment of good workmanship or in defiance of the Engineer In-Charge's instructions to the contrary sub-let any part of the contract, then and in any of the above said causes, the Purchaser with the written consent of the Engineer In-Charge may, notwithstanding any previous waiver, after giving seven days' notice in writing under the provisions of this clause to the Contractor/Supplier, determine the contract but without prejudice to the powers of the Engineer In- Charge or the obligations and liabilities of the Contract, the whole of which shall continue to be in force as if the contract has not been so determined and as if the work

- subsequently executed has been executed by and on behalf of the Contractor/ Supplier.
- 11.16.2. After the issue of such notice, the Contractor/Supplier shall not be at liberty to remove from site any equipment, tools and materials belonging to him which shall have been placed thereon for the purpose of the works and the Purchaser shall have lien upon such equipment, tools or materials to subsist from the date of such notice and until the notice shall have been complied with.
- 11.16.3. If the Contractor/Supplier shall fail to comply with the requirements of said notice for seven days after such notice has been given, the Purchaser shall have the power to enter upon and take possession of the works and site and all equipment, tools and materials thereon, and to engage any other person, firm or agency to complete the works, utilizing the equipment, tools and materials to the extent possible. The Purchaser shall not in any way be responsible for damage or loss of the tools, equipment and materials and the Contractor/Supplier shall not have any compensation therefore.
- 11.16.4. Upon completion of the works, the Engineer In-Charge shall certify the amount of expenditure properly incurred consequent on and incidental to the default of the Contractor/Supplier as aforesaid and such amount shall be deducted from the payments due to the Contractor/Supplier, including the Security Deposit. If the said amount exceeds the payment due to the Contractor/Supplier, the Purchaser shall be at liberty to dispose off any of the Contractor's/Supplier's materials, tools or equipment and apply the proceeds for the payments due from the Contractor/Supplier and recover the balance by process of law.
- 11.16.5. After the works have been completed after the amounts due to the Contractor/Supplier, the Engineer In-Charge shall give notice in writing to the Contractor/Supplier to remove the surplus equipment and material from site. If such equipment and materials are not removed within a period of 14 days after such notice, the Purchaser shall have the power to remove and sell the same holding the proceeds less the cost of removal and sale, to the credit of the Contractor/Supplier. The Purchaser shall not be responsible for any loss sustained by the Contractor/Supplier from the sale of the equipment and material.

13. Contractor's Representative:

- 13.1. The Contractor/Supplier shall employ at least one qualified representative (ie. Electrical supervisory License with minimum 3 years of experience of similar works as stipulated by TIFR- Hyderabad in the work order) whose name shall have previously been communicated in writing to the Engineer In-Charge and approved by him to supervise the erection. Any written order or instructions given to the representative shall be deemed to have been given to the Contractor/Supplier. The Engineer In-Charge shall be at liberty to object to any particular representative/or any persons employed by the Contractor/Supplier on the work and the Contractor/Supplier shall remove the person objected to, on the

receipt of the Engineer In-Charge, in writing, a request requiring him to do so and shall provide in his place another competent representative acceptable to the Engineer In-Charge.

- 13.2. The Contractor's/Supplier's representative shall be a qualified electrical/ mechanical engineer possessing adequate site experience in similar nature of works.

14. Completion Time:

Unless otherwise agreed in writing between the Purchaser and the Contractor/Supplier, the work contract shall be completed within the stipulated period mentioned elsewhere in this tender document from the date of Work/Purchase Order issued to Contractor/Supplier by the Purchaser.

15. Delivery of Material at Site:

The Contractor/Supplier/Manufacturer shall arrange for safe transit and delivery of material at site and unloading the material at site.

16. Validity of Tender:

The quotation should be valid for 75 days after opening of the Part—I: Technical Bids.

17. Measurements:

All joint measurements of quantities shall be done by the Contractor at his own cost in the presence of the Engineer In-Charge or any authorized person deputed by him who will certify the routes, length and quantities etc. for the purpose of determination of the amount payable.

18. Spare Parts & Manuals:

Manufacturer/Contractor/Supplier should submit operation, maintenance and spare part list and manuals for all equipment.

19. Training:

Manufacturer/Contractor/Supplier should provide training for operation and maintenance free of cost for equipment supplied.

20. Special Instruction for bidding process

This tender is a two part tender. The Part-I: Technical Bid and Part-II: Financial Bid. Bidders shall seal each bid separately with a clear label on the envelope about its content. Both the bids should be submitted in a single drop two cover method. Any pricing details must not appear in the Part-I: Technical Bid.

21. Drawings and Documentation:

As-built drawings as specified in this technical specifications shall be submitted by the Contractor.

22. Permissions and Approvals:

All statutory permissions and approvals from Electricity authority as may be required for commissioning of the entire system shall be carried out by the contractor. All necessary documentation for obtaining such permissions and approvals shall be done by the contractor. Purchaser shall assist in providing required declarations. Statutory fees shall be paid by the purchaser.

23. Guarantee:

The equipment shall be guaranteed against all design and manufacturing defects, poor workmanship etc. for a period of 12 months from the date of commissioning or 15 months from the date of supply, whichever is earlier. Any defects discovered during this period shall be rectified by the vendor free of cost to the purchaser.

1. SELECTION CRITERIA

AHUs shall be selected for the air quantity, capacity and static as mentioned in the BOQ. The following specifications are to be followed.

1. 1. FLOOR MOUNTED HORIZONTAL AIR HANDLING UNITS:

AHUs shall be selected for the air quantity, capacity and static as mentioned in the BOQ. The following specifications are to be followed.

Type of AHU	: Double Skin
Air quantity and static pressure	: As specified in the BOQ
Type of fan	: EC Fans - Multiple
AHU sections	: Mixing Box Section with prefilters, coils section with chilled water & hot water coil, fan section with EC fine filter section with fine filters.
Maximum velocity across the coil and filter:	400 FPM
Coil face area	: Full Face Area
Minimum Chilled water coil rows deep	: 6 Row As per BOQ
Minimum Hot water coil rows deep	: 2 Row As per BOQ
Coil fins per inch	: 12 FPI
Inner sheet thick	: 0.8 mm or 22 G GI
Outer sheet thick	: 0.8 mm or 22 G pre coated GI
Insulation thickness	: 50 mm thick.
Insulation Type	: Rockwool with density of 96 kg/cub.mt.
Aluminum sections	: Thermal break profile



Outlet dampers	: Al aerofoil opposed blade type
Motor Efficiency	: Shall be more than IE4
Commissioning Filters	: 50 mm thick washable EN 779:G4 filters
Permanent Filters	: Pre filter EN 779:G4 & Fine filter with EN 779:F9
Chilled water in / out temp:	: 8 / 13.6 deg. C
Certification	: Eurovent Certified
Panel	: Control & Power Panel with incoming isolator, outgoing MCBS for each fan, manual potentiometer, auto/manual Switch, etc. should be on the AHU
Noise Level – Floor Mounted	: Less than 65 dBA at 1 mt. distance

AHU shall have see-through glass, marine lamp with switch for mixing box section, coils section, fan section and fine filter section. Limit switch for the access door of the fan section. Access doors shall open outside and inside based on pressure. Shall open on the positive pressure side.

2. TECHNICAL SPECIFICATIONS

2.1. FLOOR MOUNTED HORIZONTAL AIR HANDLING UNITS (AHUs):

The scope of this section comprises the supply, erection, testing and commissioning of double skin construction factory assembled air handling units, conforming to these specifications and in accordance with requirements of Drawings & of the bill of quantities.

Unit performance, coil performance and Mechanical Characteristics shall be EUROVENT certified. The EUROVENT Certified manufacturer shall provide a detailed computerized software performance printout for overall AHU performance including coil & fan selections for each AHU in project.

The unit & its components should conform to following standards

- EN 1886** : Air handling unit mechanical performance.
- EN 13053** : Ratings and performance for units and components.
- EN 308** : Test procedure for heat exchangers.
- EN 779** : Particulate air filters for general ventilation.
- EN 1751** : Aerodynamic testing of dampers.
- EN 60204.1** : Electrical equipment of machines.
- EN ISO 3741** : Determination of sound power level in reverberation rooms.
- AMCA 210** : Aerodynamic performance testing of fans.
- AMCA 300** : Reverberant room method of sound level testing
- ISO 1940** : Static & dynamic balancing for fans.

TYPE:

The air handling units shall be double skin construction, draw through type comprising of various sections such as mixing box (as applicable in BOQ / drawings), filter section, chilled water coil and hot water coil section, humidification section, fan section, fine filter plenum fabricated (wherever required) as per details given in Drawings and bill of quantities.

AIR HANDLING UNIT PERFORMANCE:

The performance of air handling units should be tested in a Eurovent accredited laboratory in accordance with EN 13053. These tests shall be carried out for Air flow Vs static pressure data, power consumption, Heat recovery (if any), Cooling & heating duty, Air / water - side pressure drop.

CASING:

The casing of the air-handling unit shall be of 50mm double skin construction, complying with Eurovent certification for mechanical characteristics as per EN 1886. The structure shall be made of Extruded Aluminum sections with polyamide thermal break profile for ensuring thermal bridging performance. The polyamide strip should be crimped to extruded aluminum sections for leak proof fitment. The structure shall be assembled using die cast Glass filled Nylon joints to make a sturdy, strong & self-supporting framework for various sections. The profile shall have built in coved aluminum profile having smooth curvature from inside to avoid dust accumulation.

The panels shall be screwed to the structure using soft food grade gasket to make it leak proof. Air tight access doors/panels with die cast zinc hinges shall be provided for access to various sections for maintenance. The entire housing shall be mounted on 100mm high Powder coated GSS channel frame work with provision for handling the units at site. All internal blank offs, coil supports and filter frame shall be made of powder coated GI for easy maintenance and inhibition of corrosion.

- Outer skin - Pre painted Galvanised Sheet Steel of 0.8 mm thickness
- Inner skin – GI 0.8 mm thickness.
- Insulation - Rockwool insulation (density not less than 96 kg/m³)
- Gaskets to be used – EPDM type

The door shall be fitted with a double wall inspection window of 200 mm diameter and robust glass filled nylon handles operational from both sides with optional locking arrangement. Each section should have inspection doors with duly wired marine lights and on/off switch mounted on the wall of the unit. The entire housing shall be mounted on GSS channel frame work with provision for handling the units at site.

Drain Pan shall be constructed of 18 G 304 Stainless Steel with 3-way slope to facilitate immediate discharge of condensate. Specially designed drain pan with all round edges allow complete cleaning & avoid microbial growth as per ASHRAE 62- 1999 standard. The drain tray will be insulated externally with 19 mm nitrile rubber & extended at least 300 mm beyond the coil. Necessary arrangement will be provided to slide the coil in the drain pan.

PLUG FAN WITH EC MOTOR:

The complete EC Fan unit shall be of rugged bolted construction made of sheet steel, statically and dynamically balanced.

Fan: The fan section shall be equipped with a Single Inlet Centrifugal Impeller with High Efficiency Backward curved blades and external rotor EC (Electronically Commutated) motor, energy optimized for operation without spiral housing for high efficiency and favorable acoustic behavior. The high efficiency backward curved impeller with rotating diffuser, made of high-performance composite material / welded aluminum sheet material, with external rotor motor balanced together statically and dynamically according to DIN ISO 1940 Part 1.

The EC fan should be capable of being fitted in horizontal or vertical position in the AHU, depending on the application. Inlet cones shall be provided with a nozzle for volume flow measurement of the fan.

Motor: the motor shall be a permanent magnet external rotor motor with integrated electronics and suitable for continuous operation. The speed of the motor shall be variable depending on an external control signal. The fans shall be Modbus RTU compatible for communication with BMS (Building Management System). The fan in totality shall be of most efficient type so that the power consumption and noise level is minimal. The EC motor shall have a wide voltage input range: 3~380...480V, 50/60 Hz. The motor shall be minimum IP55 protection class, with Thermal class 155 (Insulation class F). The EC motor shall be provided with suitable protection from moisture & hot climate. The ball bearing shall be provided with long time lubrication for maintenance free operation.

Integrated Electronics: The device electronics shall be protected from overload by the Active Temperature Management, so that if the ambient operating temperature exceeds the design limit, then the fan is not switched off immediately. In such a condition the fan should be operational at lower speeds, till the time the operating ambient temperature drops down.

The EC motor shall meet all necessary EMC (Electromagnetic Compatibility) directives. The EC motor should comply with applicable EMC standards: Interference Emission Standard EN 61000-6-3 / 2. EC Motor shall be Integrated with VSD (Variable Speed Drive) for speed modulation of fans.

Fan characteristic curves shall be related to measurements on a fan test rig with inlet silencing chamber in accordance with DIN 24163 Part 2 OR ISO 5801.

The performance data of the fan shall correspond to precision class 2 as defined by DIN 24166.

The EC motor shall have the following protective features integrated in the controller:

- Overvoltage protection
- Short Circuit protection
- Under voltage/ Over voltage detection
- Locked rotor protection
- Line fault detection
- Active Temperature Management for thermal protection of motor and electronics
- Alarm relay 250V/2A
- Over temperature protection of electronic and motor
- External LED display shall be provided for indication of the status of the fan

COOLING/HEATING COILS:

1.1 Chilled/hot water coil shall have 12.7 mm dia tubes minimum 0.4 m m thick with 0.15 mm thick waffle/ripple aluminum fins firmly bonded to copper tubes assembled in zinc coated steel frame.

1.2 Face & surface areas shall be such as to ensure rated capacity from each unit & such that air velocity across each coil shall not exceed 122 meters per minute (400 FPM).

1.3 The coil shall be pitched in the unit casing for proper drainage. Each coil shall be factory tested at 21 Kg per sq.cm (300 psig) air pressure under water. Tube shall be mechanically expanded for minimum thermal contact resistance with fins. Fin spacing shall be 10 to 12 fins per inch (4 to 5 fins per cm). Coils shall be provided with copper header and MS adaptor. Performance of Coil in accordance as per EN 1216 standard with a maximum tolerance of 5%.

FILTERS

All filters in the AHUs shall be mounted on a powder coated GI holding frame.

Primary Filters

Filter banks shall be easily accessible and designed for easy removal and renewal of filter cells. Pre filters shall be 50mm deep synthetic washable type EN 779: G4 pre filter. Filter depth should not be less than 50 mm. Filter frame shall be made of 18 G GI.

Secondary Filters.

Fine filters section shall be at the outlet of the fan. Fine filter section shall have fine filters, provision for connecting the supply duct with a damper. Fine filters section shall have provision to bleed off the air if required. Fine filter section shall have an access door, marine lamp, switch, etc.

Filter banks shall be easily accessible and designed for easy removal and renewal of filter cells. EN 779: F9 fine filter with 300mm deep shall be provided. Filter frame shall be made of 18G GI.

ELECTRICAL & CONTROL PANEL:

The air handling unit shall have inbuilt integrated electrical starter panel with AUTO/Manual override switch for operation. Control cabinet to be provided with IP 65 enclosure which should be mounted on AHU surface/flushed inside the AHU casing. The electric panel provided for the unit must be equipped with main incoming contactor additionally the unit must be provided with MCBs with busbar for single incomer provision, additionally SMPS must be provided for power supply to the unit controller. Potentiometer shall be an integral part of the panel for manual speed control. Each unit shall have an Internal mounted Power cum control marshaling box of IP 65 protection with door and hinges with provision to mount power and control wirings with DDC controller. Provision for 24 V DC power supply for PIBCV valve shall be part of the control panel.

SAFETY FEATURES

Each Air Handling Unit must have safety features as under:

- a) The Fan Access Door shall be equipped with a micro-switch interlocked with a fan motor to enable switching off the fan motor automatically in the event of door opening.
- b) The Access Door shall further have a wire mesh screen as an added safety feature bolted on to the unit frame.
- c) Fan and motor base shall be properly grounded.
- d) EC fan grounding within the fan terminal (if applicable)



LIST OF APPROVED MAKES

SL. NO.	ITEM	APPROVED MAKES
1	AHU'S	System Air/Flakewood/Equivalent
2	EC FANS	EBM/Ziehl-abegg/Equivalent



SECTION-V

ANNEXURES

ANNEXURE I

FORM OF PERFORMANCE GUARANTEE (BY BANK GUARANTEE)

1. In consideration of the TIFR-Hyderabad, Hyderabad having agreed under the terms and conditions of Letter of Intent / Agreement No..... dated..... made between and..... (Here in after..... called "the said Contractor(s)") for the work (Here in after called "the said Letter of Intent / Agreement") having agreed to production of a irrevocable bank Guarantee for Rs..... (Rupees only), as a security / guarantee from the contractor(s) for compliance of his obligations in accordance with the terms and conditions in the said agreement, we(Indicate the name of the Bank) (hereinafter referred to as "the Bank") Here by undertake to pay to TIFR an amount not exceeding Rs. (Rs only) on demand by TIFR.

2. We..... (indicate the name of Bank) do hereby undertake to pay the amounts due and payable under this guarantee without any demur, merely on a demand from TIFR stating that the amount claimed is required to meet the recoveries due or likely to be due from the said Contractor(s). Any such demand made on the bank shall be conclusive as regards the amount due and payable by the Bank under this guarantee. However, our liability under this guarantee shall be restricted to an amount not exceeding Rs..... (Rupees..... only).

3. We, the said bank, further undertake to pay to TIFR any money so demanded notwithstanding any dispute or disputes raised by the Contractor(s) in any suit or proceeding pending before any Court or Tribunal relating thereto, our liability under this present being absolute and unequivocal. The payment made by us under this bond shall be a valid discharge of our liability for payment thereunder and the Contractor(s) shall have no claim against us for making such payment.

4. We (indicate the name of Bank) further agree that the guarantee herein contained shall remain in full force and effect during the period that would be taken for the performance of the said Agreement and that it shall continue to be enforceable till all the dues of TIFR under or by virtue of the said Agreement have been fully paid and its claims satisfied or discharged or till Engineer-in-charge on behalf of the TIFR certifies that the terms and conditions of the said Agreement have been fully and properly carried out by the said Contractor(s) and accordingly discharges this guarantee.

5. We (indicate the name of Bank) further agree with TIFR that TIFR shall have the fullest liberty without our consent and without affecting in any manner our obligations hereunder to vary any of the terms and conditions of the said Agreement or to extend time of performance by the said Contractor(s) from time to time or to postpone for any time or from time to time any of the powers exercisable by TIFR against the said Contractor(s) and to forbear or enforce any of the terms and conditions relating to the said Agreement and we shall not be relieved from our liability by reason of any such variation, or extension being granted to the said Contractor(s) or for any forbearance, act of omission on the part of TIFR or any indulgence by TIFR to the said Contractor(s) or by any such matter or thing whatsoever which under the law relating to sureties would, but for this provision, have effect of so relieving us.

6. This guarantee will not be discharged due to the change in the constitution of the Bank or the Contractor(s).

7. We,..... (indicate the name of Bank) lastly undertake not to revoke this guarantee except with the previous consent of TIFR in writing.

8. This guarantee shall be valid up to, unless extended on demand. Notwithstanding anything mentioned above, our liability against this guarantee is restricted to Rs (Rupees only) and unless a claim in writing is lodged with us within six months of the date of expiry or the extended date of expiry of this guarantee, all our liabilities under this guarantee shall stand discharged.

Signed and sealed

Dated the day of..... for..... (indicate the name of Bank) *(Note: The Letter of Intent shall form part of the Agreement)



ANNEXURE II

UNDERTAKING BY THE TENDERER

I / We have read and examined the Tender document including terms & conditions, specifications, Schedule of quantities, drawings and designs, general rules & directions, General Conditions of Contract, Special Conditions of Contract and all relevant other documents, publications and rules referred to in the Conditions of Contract and all other contents in the tender documents for the work.

I / We, hereby tender for execution of the work specified for the TIFR-Hyderabad, Hyderabad within the time specified and in accordance in all respects with the specifications, designs, drawings and instructions in writing.

We agree to keep the tender open for seventy five (75) days from the last date of its submission and not to make any modifications in its terms and conditions. A sum of Rs..... has been deposited in cash / receipt treasury challan / deposit at call receipt of scheduled bank / fixed deposit receipt of scheduled bank / demand draft of a scheduled bank / Bank Guarantee issued by a Scheduled Bank as earnest money. If I / we, fail to furnish the prescribed performance guarantee within prescribed period, I / we agree that the said TIFR-Hyderabad, Hyderabad or its authorized officer shall without prejudice to any other right or remedy, be at liberty to forfeit the said earnest money absolutely. Further, if I / we fail to commence work as specified, I / we agree that the TIFR-Hyderabad, Hyderabad shall without prejudice to any other right or remedy available in law, be at liberty to forfeit the said earnest money and the performance guarantee absolutely, otherwise the said earnest money shall be retained by TIFR- Hyderabad, Hyderabad towards security deposit to execute all the works referred to in the tender documents upon the terms and conditions contained or referred to therein.

Further, I / We agree that in case of forfeiture of earnest money or both Earnest Money & Performance Guarantee as aforesaid, I / We shall be debarred for participation in the re-tendering process of the work.

I / We hereby declare that I / We shall treat the tender documents, drawings and other records connected with the work as secret / confidential documents and shall not communicate information derived there-from to any person other than a person to whom I / We am / are authorized to communicate the same or use the information in any manner prejudicial to the safety of the State.

Seal & Signature of Contractor Postal Address

Dated

Witness Address Occupation



ANNEXURE-III

CERTIFICATE OF LOCAL CONTENT

***We [name of manufacturer] hereby confirm in respect of quoted item(s) that local Content is equal to or more than 50% and come under 'Class-I Local Supplier' Category. As being 'Class-I Local Supplier', we are eligible for Purchase Preference under 'Make in India' Policy vide Gol Order No.P-45021/2/2017-PP (B.E.-II) dated 15.06.2017 (subsequently revised vide orders dated 28.05.2018, 29.05.2019 and 04.06.2020)**

OR

***We [name of manufacturer] hereby confirm in respect of quoted items(s) that Local Content is more than 20% but less than 50% and come under 'Class-II Local Supplier' Category.**

The details of the location (s) at which the local value addition made is / are under:

1.

2.

Date:


Seal & Signature of the Bidder

NOTE:

Self-certification that the item offered meets the minimum local content (as above) giving details of the location(s) at which the local value addition is made in case the bidder wishes to avail the benefits under the make in India policy, if applicable.

In cases of procurement for a value in excess of Rs.10 crores, the local supplier shall be required to provide a certificate from the statutory auditor or cost auditor of the company (in the case of companies) or from a practicing cost accountant or practicing chartered accountant (in respect of suppliers other than companies) giving the percentage of local content to avail the benefits under the make in India policy, if applicable.

ANNEXURE-IV



TECHNICAL DATA SHEETS

SL.NO.	PARAMETER	DETAILS
1.0	AIR HANDLING UNIT	
1.1	Make	
1.2	Model	
1.3	Type	
1.4	Capacity (TR)	
1.5	Air Quantity (Cfm)	
1.6	Total Static Pressure (mm of Wg)	
1.7	External Static Pressure (mm of Wg)	
1.8	Noise level at 1mt.distance from filter section at 1mt height (dBA)	
1.9	Inner Skin	
1.10	Outer Skin	
1.11	Type of Insulation	
1.12	Thickness of Insulation	
1.13	Density of Insulation	
1.14	Thermal Conductivity of Insulation	
1.15	Thickness of aluminum extrusions	

1.16	Aluminium Extrusions – Thermal Break / Non Thermal Break	
1.17	Material & thick of base frame	
2	FAN SECTION:	
2.1	Make	
2.2	Model	
2.3	Type of fan	
2.4	No.of fans	
2.5	Motorized damper at outlet of fan	
2.6	Air Quantity (Cfm)	
2.7	Total Static Pressure (mm of Wg)	
2.8	Speed (RPM)	
2.9	Break Horse Power (Kw)	
2.10	Motor Rating (Kw)	
2.11	Fan Outlet Velocity (mt./sec)	
2.12	Noise level (dBA)	
2.13	Fan Efficiency (%)	
2.14	Motor Efficiency (%)	
3	COOLING COIL SECTION:	
3.1	Face Area (sq.mt.)	
3.2	Tube dia.(mm)	
3.3	Tube length (mm)	



TATA INSTITUTE OF FUNDAMENTAL RESEARCH

(Autonomous Institution of the Department of Atomic Energy, Government of India)
Survey No.36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District,
Hyderabad-500046, Telangana

3.4	Tube high (mm)	
3.5	Tube pitch (mm)	
3.6	No.of rows	
3.7	No.of fins per inch	
3.8	Face Velocity (FPM)	
3.9	Entering air temp. DB / WB (deg.F)	
3.10	Leaving air temp. DB / WB (deg.F)	
3.11	Air side pressure drop (mm of Wg.)	
3.12	Refrigerant Flow (USGPM)	
3.13	Refrigerant Temp.in (deg.F)	
3.14	Refrigerant Temp.out (deg.F)	
3.15	Refrigerant side pressure drop (PSI)	
3.16	Capacity of the Coil (TR)	
4	HEATING COIL SECTION:	
4.1	Face Area (sq.mt.)	
4.2	Face Velocity (FPM)	
4.3	Hot Water Flow Rate (USGPM)	
4.4	Hot Water In Temp. (deg. F)	
4.5	Hot Water Out Temp. (deg. F)	
4.6	Hot Water Side Pressure Drop (mm of Wg)	
4.7	Entering air temp.DB / WB (deg.F)	

4.8	Leaving air temp.DB / WB (deg.F)	
4.9	Air side pressure drop (mm of Wg.)	
4.10	Capacity of Heating Coil (KW)	
5	PRE FILTERS:	
5.1	Filter Area (Sq.mt.)	
5.2	Air Velocity Across the Filter (mt./ sec)	
5.3	Pressure drop across the filter clean / dirty (mm of Wg.)	
5.4	No.of filters	
5.5	Size of filter (mm x mm x mm)	
5.6	EN 779:G4	
5.7	Commissioning Filters	
6	FINE FILTERS:	
6.1	Filter Area (Sq.mt.)	
6.2	Air Velocity Across the Filter (mt./ sec)	
6.3	Pressure drop across the filter clean / dirty (mm of Wg.)	
6.4	No. of filters	
6.5	Size of filter (mm x mm x mm)	
6.6	EN 779:F9	
7	SECTIONS:	
7.1	Mixing Box Section	



7.2	Coil Section	
7.3	Fan Section	
7.4	Fine Filter Section	
8	DAMPERS:	
8.1	Supply Air	
8.2	Return Air	
8.3	Fresh Air	
8.4	Bleed Off Damper	
9	ACCESSORIES:	
9.1	View Port, Marine Lamp with Switch in mixing box section, fan section, coil section and fine filter section	
9.2	Limit Switch for blower section access door	
9.3	Pressure sensing probes for pre filters and fine filters	

Note: Enclose coil and fan selection sheet with operating points



SECTION-VI

FINANCIAL BID

INVITATION OF BIDS FOR

**Supply, Installation, Testing and Commissioning of Air Handling Units for
Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village),
Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.**

PART II

FINANCIAL BID



TATA INSTITUTE OF FUNDAMENTAL RESEARCH
(Autonomous Institution of the Department of Atomic Energy, Government of India)
Survey No.36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District,
Hyderabad-500046, Telangana

SCHEDULE OF QUANTITIES

S.NO	DESCRIPTION	Units	Qty(A)	Rate(B)	Amount (C=A*B)
1.	<p>Supply, Installation, Testing & Commissioning of Eurovent certified Double Skin Floor mounted Air Handling Units complete with double skin 50 mm thick insulated with Fire retardant 96Kg/m³ high density Rockwool insulation panels sandwiched between 0.8 mm thick GI inner & 0.8 mm pre-coated GI outer sheets.</p> <p>The AHU casing shall comply with Eurovent standard EN 1886.</p> <p>The control wiring and power wiring shall be in the scope of AHU manufacturer and to be carried out at factory with terminations to Marshaling box (Applicable for EC Fan).</p> <p>EPDM gasket to be provided between panels and structure of the AHU to ensure the entire housing is airtight.</p> <p>100mm heavy duty GSS baseframe & all internal blank offs / coil supports and filter frame shall be GI powder coated for better aesthetics, cleaning and maintenance.</p> <p>Aluminum profiles shall be with thermal break.</p> <p>AHU shall contain mixing box section with pre-filters, coil section with 6 row chilled water coil & 2 row hot water coil, fan section with EC fans & fine filter section.</p> <p>Pre filters shall be 50 mm thick washable EN 779:G4 filters with frame and fine filters shall be 300 mm deep EN 779:F9 fine filters along with frame.</p> <p>A set of commissioning pre filters to be supplied for start-up activities.</p>	Units	03		



TATA INSTITUTE OF FUNDAMENTAL RESEARCH

(Autonomous Institution of the Department of Atomic Energy, Government of India)
Survey No.36/P, Gopanpally Village, Serilingampally Mandal,Ranga Reddy District,
Hyderabad-500046, Telangana

<p>Face Velocity across the coils and filters should not exceed 400 FPM. Aluminum profiles shall have internal coving.</p> <p>The AHU shall be supplied with AHU blower fans with wall mounted EC PLUG Fan (EBM / Ziehl-abegg) complete with external rotor BLDC motor & integrated electronic controller, potentiometer for speed control. The fan shall be suitable for BMS connectivity. Single or multiple fans shall be considered depending upon capacity of AHUs. AHU manufacturers should supply cover plates for Fans in sufficient quantity for maintenance purposes. EC fan incoming supply to be terminated with MCB, each fan shall have separate outgoing MCB and shall be included in the power terminal box for electrical connection of EC fans and should be factory fitted on the AHUs. Potentiometer shall be provided in the marshaling box for manual operation of EC fans. Relay for AUTO/MANUAL operation should be a part of the Marshalling box supplied by the AHU manufacturer. AHUs shall be supplied in fully assembled condition from the factory as a single unit or in modules and shall be installed at site with a crane. Modules shall be connected at site. Control panel to be provided with a rotary switch to ON/OFF the fan through manual by override .Apart from that there will be an option to ON/OFF ahu by controller Keypad and also from BMS. A potentiometer with auto/manual switch to be provided so an override of fan speed through manual should be possible. Main incoming MCB, individual MCB for each fan, busbar, 1 no. Contactor to distribute power to individual fan should be provided. The AHU casing shall comply with Eurovent standard EN 1886 for casing strength D1, Casing Air leakage L1, Thermal Bridging factor TB2, Thermal Transmittance T2 & Filter bypass leakage F9.</p>				
--	--	--	--	--



TATA INSTITUTE OF FUNDAMENTAL RESEARCH

(Autonomous Institution of the Department of Atomic Energy, Government of India)
 Survey No.36/P, Gopanpally Village, Serilingampally Mandal,Ranga Reddy District,
 Hyderabad-500046, Telangana

	<p>AHU-1 Zone-1 (PW Laser Hall,Main change room,Optic lab & Lab-1&2)</p> <p>26.5TR / 21600 CFM at 85 MMWG External static.(2W+1S)</p>				
2.	<p>Supply,Installation, Testing & Commissioning of Eurovent certified Double Skin Floor mounted Air Handling Units complete with double skin 50 mm thick insulated with Fire retardant 96Kg/m3 high density Rockwool insulation panels sandwiched between 0.8 mm thick GI inner & 0.8 mm precoated GI outer sheets.</p> <p>The AHU casing shall comply with Eurovent standard EN 1886.</p> <p>The control wiring and power wiring shall be in the scope of AHU manufacturer and to be carried out at factory with terminations to Marshaling box (Applicable for EC Fan).</p> <p>EPDM gasket to be provided between panels and structure of the AHU to ensure the entire housing is airtight.</p> <p>100mm heavy duty GSS baseframe & all internal blank offs / coil supports and filter frame shall be GI powder coated for better aesthetics, cleaning and maintenance.</p> <p>Aluminum profiles shall be with thermal break.</p> <p>AHU shall contain mixing box section with prefilters, coil section with 6 row chilled water coil & 2 row hot water coil, fan section with EC fans & fine filter section.</p> <p>Pre filters shall be 50 mm thick washable EN 779:G4 filters with frame and fine filters shall be 300 mm deep EN 779:F9 fine filters along with frame.</p> <p>A set of commissioning pre filters to be supplied for start-up activities.</p>	Units	02		



TATA INSTITUTE OF FUNDAMENTAL RESEARCH

(Autonomous Institution of the Department of Atomic Energy, Government of India)
Survey No.36/P, Gopanpally Village, Serilingampally Mandal,Ranga Reddy District,
Hyderabad-500046, Telangana

<p>Face Velocity across the coils and filters should not exceed 400 FPM. Aluminum profiles shall have internal coving.The AHU shall be supplied with AHU blower fans with wall mounted EC PLUG Fan (EBM / Ziehl-abegg) complete with external rotor BLDC motor & integrated electronic controller, potentiometer for speed control. The fan shall be suitable for BMS connectivity. Single or multiple fans shall be considered depending upon capacity of AHUs. AHU manufacturers should supply cover plates for Fans in sufficient quantity for maintenance purposes. EC fan incoming supply to be terminated with MCB, each fan shall have separate outgoing MCB and shall be included in the power terminal box for electrical connection of EC fans and should be factory fitted on the AHUs. Potentiometer shall be provided in the marshaling box for manual operation of EC fans. Relay for AUTO/MANUAL operation should be a part of the Marshalling box supplied by the AHU manufacturer. AHUs shall be supplied in fully assembled condition from the factory as a single unit or in modules and shall be installed at site with a crane. Control panel to be provided with a rotary switch to ON/OFF the fan through manual by override .Apart from that there will be an option to ON/OFF ahu by controller Keypad and also from BMS. A potentiometer with auto/manual switch to be provided so an override of fan speed through manual should be possible. Main incoming MCB, individual MCB for each fan, busbar, 1 no. Contactor to distribute power to individual fan should be provided. Modules shall be connected at site. The AHU casing shall comply with Eurovent standard EN 1886 for casing strength D1, Casing Air leakage L1, Thermal Bridging factor TB2, Thermal Transmittance T2 & Filter bypass leakage F9.</p>				
--	--	--	--	--



TATA INSTITUTE OF FUNDAMENTAL RESEARCH

(Autonomous Institution of the Department of Atomic Energy, Government of India)
Survey No.36/P, Gopanpally Village, Serilingampally Mandal,Ranga Reddy District,
Hyderabad-500046, Telangana

	AHU-2 Zone-2&3 (PW Laser Service corridor & Service corridor (future))25TR / 13800 CFM at 50 MMWG External static.(1W+1S)				
3.	<p>Supply,Installation, Testing & Commissioning of Eurovent certified Double Skin Floor mounted Air Handling Units complete with double skin 50 mm thick insulated with Fire retardant 96Kg/m3 high density Rockwool insulation panels sandwiched between 0.8 mm thick GI inner & 0.8 mm precoated GI outer sheets.</p> <p>The AHU casing shall comply with Eurovent standard EN 1886.</p> <p>The control wiring and power wiring shall be in the scope of AHU manufacturer and to be carried out at factory with terminations to Marshaling box (Applicable for EC Fan).</p> <p>EPDM gasket to be provided between panels and structure of the AHU to ensure the entire housing is airtight.</p> <p>100mm heavy duty GSS baseframe & all internal blank offs / coil supports and filter frame shall be GI powder coated for better aesthetics, cleaning and maintenance.</p> <p>Aluminum profiles shall be with thermal break.</p> <p>AHU shall contain mixing box section with prefilters, coil section with 6 row chilled water coil & 2 row hot water coil, fan section with EC fans & fine filter section.</p> <p>Pre filters shall be 50 mm thick washable EN 779:G4 filters with frame and fine filters shall be 300 mm deep EN 779:F9 fine filters along with frame.</p> <p>A set of commissioning pre filters to be supplied for start-up activities.</p> <p>Face Velocity across the coils and filters should not exceed 400 FPM.</p>	Units	02		



TATA INSTITUTE OF FUNDAMENTAL RESEARCH

(Autonomous Institution of the Department of Atomic Energy, Government of India)
Survey No.36/P, Gopanpally Village, Serilingampally Mandal,Ranga Reddy District,
Hyderabad-500046, Telangana

<p>Aluminum profiles shall have internal coving.The AHU shall be supplied with AHU blower fans with wall mounted EC PLUG Fan (EBM / Ziehl-abegg) complete with external rotor BLDC motor & integrated electronic controller, potentiometer for speed control.</p> <p>The fan shall be suitable for BMS connectivity. Single or multiple fans shall be considered depending upon capacity of AHUs.</p> <p>AHU manufacturers should supply cover plates for Fans in sufficient quantity for maintenance purposes. EC fan incoming supply to be terminated with MCB, each fan shall have separate outgoing MCB and shall be included in the power terminal box for electrical connection of EC fans and should be factory fitted on the AHUs. Potentiometer shall be provided in the marshaling box for manual operation of EC fans.</p> <p>Relay for AUTO/MANUAL operation should be a part of the Marshalling box supplied by the AHU manufacturer.</p> <p>AHUs shall be supplied in fully assembled condition from the factory as a single unit or in modules and shall be installed at site with a crane.</p> <p>Modules shall be connected at site.Control panel to be provided with a rotary switch to ON/OFF the fan through manual by override .Apart from that there will be an option to ON/OFF ahu by controller Keypad and also from BMS. A potentiometer with auto/manual switch to be provided so an override of fan speed through manual should be possible. Main incoming MCB, individual MCB for each fan, busbar, 1 no. Contactor to distribute power to individual fan should be provided.</p> <p>The AHU casing shall comply with Eurovent standard EN 1886 for casing strength D1, Casing Air leakage L1, Thermal Bridging factor TB2, Thermal Transmittance T2 & Filter bypass leakage F9.</p>				
---	--	--	--	--



TATA INSTITUTE OF FUNDAMENTAL RESEARCH

(Autonomous Institution of the Department of Atomic Energy, Government of India)
Survey No.36/P, Gopanpally Village, Serilingampally Mandal,Ranga Reddy District,
Hyderabad-500046, Telangana

	AHU-3 Zone-4(PW Laser Plasma Room,Changing Room,Shoes Changing Room) 19.5TR / 27000 CFM at 85 MMWG External static.(1W+1S)				
4.	<p>Supply,Installation, Testing & Commissioning of Eurovent certified Double Skin Floor mounted Air Handling Units complete with double skin 50 mm thick insulated with Fire retardant 96Kg/m3 high density Rockwool insulation panels sandwiched between 0.8 mm thick GI inner & 0.8 mm precoated GI outer sheets.</p> <p>The AHU casing shall comply with Eurovent standard EN 1886.</p> <p>The control wiring and power wiring shall be in the scope of AHU manufacturer and to be carried out at factory with terminations to Marshaling box (Applicable for EC Fan).</p> <p>EPDM gasket to be provided between panels and structure of the AHU to ensure the entire housing is airtight.</p> <p>100mm heavy duty GSS baseframe & all internal blank offs / coil supports and filter frame shall be GI powder coated for better aesthetics, cleaning and maintenance.</p> <p>Aluminum profiles shall be with thermal break.</p> <p>AHU shall contain mixing box section with prefilters, coil section with 6 row chilled water coil & 2 row hot water coil, fan section with EC fans & fine filter section.</p> <p>Pre filters shall be 50 mm thick washable EN 779:G4 filters with frame and fine filters shall be 300 mm deep EN 779:F9 fine filters along with frame.</p> <p>A set of commissioning pre filters to be supplied for start-up activities.</p>	Units	01		



TATA INSTITUTE OF FUNDAMENTAL RESEARCH

(Autonomous Institution of the Department of Atomic Energy, Government of India)
Survey No.36/P, Gopanpally Village, Serilingampally Mandal,Ranga Reddy District,
Hyderabad-500046, Telangana

<p>Face Velocity across the coils and filters should not exceed 400 FPM. Aluminum profiles shall have internal coving.The AHU shall be supplied with AHU blower fans with wall mounted EC PLUG Fan (EBM / Ziehl-abegg) complete with external rotor BLDC motor & integrated electronic controller, potentiometer for speed control. The fan shall be suitable for BMS connectivity. Single or multiple fans shall be considered depending upon capacity of AHUs. AHU manufacturers should supply cover plates for Fans in sufficient quantity for maintenance purposes. EC fan incoming supply to be terminated with MCB, each fan shall have separate outgoing MCB and shall be included in the power terminal box for electrical connection of EC fans and should be factory fitted on the AHUs. Potentiometer shall be provided in the marshaling box for manual operation of EC fans. Relay for AUTO/MANUAL operation should be a part of the Marshalling box supplied by the AHU manufacturer. AHUs shall be supplied in fully assembled condition from the factory as a single unit or in modules and shall be installed at site with a crane. Control panel to be provided with a rotary switch to ON/OFF the fan through manual by override .Apart from that there will be an option to ON/OFF ahu by controller Keypad and also from BMS. A potentiometer with auto/manual switch to be provided so an override of fan speed through manual should be possible. Main incoming MCB, individual MCB for each fan, busbar, 1 no. Contactor to distribute power to individual fan should be provided. The AHU casing shall comply with Eurovent standard EN 1886 for casing strength D1, Casing Air leakage L1, Thermal Bridging factor TB2, Thermal Transmittance T2 & Filter bypass leakage F9.</p>				
--	--	--	--	--



TATA INSTITUTE OF FUNDAMENTAL RESEARCH
(Autonomous Institution of the Department of Atomic Energy, Government of India)
Survey No.36/P, Gopanpally Village, Serilingampally Mandal,Ranga Reddy District,
Hyderabad-500046, Telangana

	AHU-4 Zone-5 (PW Building Foyer & 3mt Wide Corridors,Diag Area) 15TR / 6150 CFM at 50 MMWG External static.AHU shall have EC fans with N+1 configuration.N working and one stand by fan.				
					Sub-Total(A)
					GST@28%(B)
					Total Amount(A+B)in Rs.
Total Amount in Words RupeesOnly					



TATA INSTITUTE OF FUNDAMENTAL RESEARCH
(Autonomous Institution of the Department of Atomic Energy, Government of India)
Survey No.36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District,
Hyderabad-500046, Telangana

SCHEDULE OF QUANTITIES

Note:

- 1. Please mention the item rate in figures and also in words.**
- 2 Rates are all inclusive of profit, Transport, Loading & Unloading, Shifting and positioning Taxes, Etc.**
- 3. TIFR, Hyderabad has right to delete any of above items from scope of work or may increase/reduce quantities as per its requirement during execution of work. No claim or compensation for such deletion/increase/decrease will be accepted/paid to the contractor. Payment will be made as per actual quantities executed at tender rates**
- 4. Manufacturer's warranty of respective supply items to be provided.**
- 5. For any above item quantity exceeding more than 10% of projected qty, contractor shall take prior approval from TIFR Engineer in writing.**
- 6. For any deviating items, the contractor shall take prior approval from TIFR Engineer In charge with proper rate analysis.**